



WE ARE YOUR SCHOOLS

---

FORT WAYNE COMMUNITY SCHOOLS

**Bid # – BD 101462**  
**January 7, 2019**

**Questions and Answers**

#	Date	Question/Answer
1.	1/4/19	Q: Will the UPS's be shipping to one location or multiple?  A: The product will be shipped to one location. There could be multiple shipments for the purchase of the UPS's over the course of the E-rate funding year.
2.	1/4/19	Q: Do you need a lift gate or is a loading dock available?  A: There is a loading dock.
3.	1/4/19	Q: Do you need inside delivery?  A: No.
4.	1/4/19	Q: Is there a freight elevator?  A: Not applicable.
5.	1/7/19	Q: What equipment will you be using these with? A switch, a server, something else?  A: FWCS uses these UPS's to protect our switches, routers, VOIP system(s), etc.
6.	1/7/19	Q: May we have the model number of that equipment?  A: Not needed. We are asking for an APC Smart-UPS SMX1500RM2UNC, or equivalent device. Specifications for equivalent device alternatives MUST be matched (equal to or better than).
7.	1/7/19	Q: How long do you wish to keep the equipment running? 5 minutes, 10 minutes, long enough to shut it down?  A: Run time depends on the load within the communication closet. We have standardized on these UPS specifications to meet our needs.

***Purchasing Department***

1200 South Clinton Street • Fort Wayne, IN 46802 • Phone: 260.467.2065 • Fax: 260.467.1976